

VENTILATION SYSTEM OVERVIEW

This template has been developed to support school districts in sharing information on ventilation systems at the school level. This includes information on how systems meet requirements for regular inspection and maintenance, and additional mitigations that have been put in place to promote student and staff safety throughout the pandemic.

School District:	64 - Gulf Islands
School Name:	Galiano Island Community School
REQUIREMENT: Regular inspection and maintenance of HVAC systems	Yes/No: Yes
	Date of last inspection: Late September Click to enter a date.
	Date of next inspection: Late October Click to enter a date.
	Date and type of most recent maintenance: Daily monitoring of Direct Digital Control (DDC) system. Monthly physical inspection for proper function of HVAC systems and MERV-13 filter status.
RECOMMENDATION: Increase supply of outside air	Yes/No: Yes
	Detail: Air dampers set to maximize outside air exchange. Extended HVAC schedule from 6am to 5pm.
RECOMMENDATION: Upgrade filtration, including installing MERV-13 filters, where possible	Yes/No: Yes
	Detail (Including filter grade): MERV-13
RECOMMENDATION: Use other air cleaning or treatment technologies	Yes/No: No
	Detail:
RECOMMENDATION: Manage energy use and air distribution through building automation control systems	Yes/No: Yes
	Detail: Managed centrally and monitored daily through DDC system.
Other Relevant Information:	CO2 sampling done weekly from late September 2022.
District Contact for any Questions:	Name: Plant Services.
	Phone Number: 250-537-5723